IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joseph Sloan DATE 7-13-82 PERMIT NO.

PHONE: Business Home

LOCATION I-77 S TL on Amity Hill Rd Past Starlite Lake TL on Small dirt St ½ mi S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 5 No. Bathrooms 4

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 45.17 acres

Character & Porosity of Soil Cecil Sandy Clay
Percolation Rate .75 gal/sq ft/day
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations none

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1020 Linear Ft. 340
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Ed O'Keeffe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 7-13-82

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

MAY. 29, 19;5 5:12