1:00 2:00

- COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

PROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

LT # 174620 PIN # ~~4761-13-7937~~ 4761136998 DATE 8-29-12

OWNER BRAZOS DEV. LLC APPLICANT: MIKE ATHANAS PHONE: Home/Cell # 704-201-6532 Business #

SITE ADDRESS 108 WHEATFIELD DR. OWNER / APPLICANT ADDRESS PO BOX 1159 TROUTMAN 28166

SITE DIRECTIONS OSTWALT AMITY, TR WHEATFIELD, 1ST ON R

SUBDIVISION WHEATFIELD BLOCK / SECTION LOT # 2 LOT AREA DESIGN FLOW 360 L.T.A.R. .225

Septic Tank 1000 Gallons: STB 786 Date 1/5/12

Pump Tank 1000 Gallons: P T 32 Date 8/5/12

Pump Make Goulds Model WE0511H Serial #

No. Nitrification Fields: 1 No. Lines 4 Linear Feet 400'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type I II (III)B IV V VI

System Description: PM - 25% REDUCTION

Repair System Description: DRIP

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 3

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

INITIAL SITE SKETCH

SEE APPROVED PLAN BY MIKE ATHANAS

AS BUILT SKETCH

*LOTS MUST BE COMBINED BEFORE OP ISSUED.

GOULDS WATER TECHNOLOGY

WE0511H

SUBMERSIBLE PUMP

1/2HP 1/60/115 3.56" 14.5MA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☒ ***IMPROVEMENT PERMIT*** *with plat valid without expiration. site plan valid 60 mo.* ☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Date 10-4-12 Installed by: ADAN CLEMENTE

IMPROVEMENT PERMIT by: REHS Date 8-29-12 OPERATION PERMIT by: REHS Date 1-11-13

AUTHORIZATION TO CONSTRUCT by: REHS Date 10-4-12 Existing System Inspected by: REHS Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy -- Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Ow