DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES — DRAFT
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
DATE: ____
COUNTY: ____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Arthur Mahon — OWNER ___ AGENT: ___ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED ____
PROPOSED FACILITY: ____
PROPERTY SIZE: 1/2 acre +
LOCATION OF SITE: Beechwood II lot 39
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS	
1	linear 6%	0 to 8	cl	SBK	1:1			.1942 Wetness Cond. -	N/A
		8 to 30	C	SBK	1:1			.1943 Depth/.1956 Sapr. -	N/A
		30 to 48	cl	weak SBK	1:1			.1944 Restrictive Hori. -	N/A
								.1948 Profile Class. -	PS
								Profile LTAR -	.35
2	linear 6%	0 to 8	cl	SBK	1:1			.1942 Wetness Cond. -	N/A
		8 to 30	C	SBK	1:1			.1943 Depth/.1956 Sapr. -	N/A
		30 to 48	cl	weak SBK	1:1			.1944 Restrictive Hori. -	N/A
								.1948 Profile Class. -	PS
								Profile LTAR -	.3
3	linear 6%	0 to 8	scl	SBK	1:1			.1942 Wetness Cond. -	N/A
		8 to 24	C	SBK	1:1			.1943 Depth/.1956 Sapr. -	N/A
		24 to 48	scl	weak SBK	1:1			.1944 Restrictive Hori. -	N/A
								.1948 Profile Class. -	PS
								Profile LTAR -	.35
4 Pit	~~4%~~ 6%	0 to 8	l	GR				.1942 Wetness Cond. -	N/A
		8 to 24	C	SBK	1:1			.1943 Depth/.1956 Sapr. -	N/A
		24 to 48	scl	weak SBK	1:1			.1944 Restrictive Hori. -	N/A
								.1948 Profile Class. -	PS
								Profile LTAR -	.35

AVAILABLE SPACE (.1945) yes — OTHER FACTORS (.1946): ____ — SITE CLASSIFICATION (.1948): PS
SYSTEM TYPE: Conv. Gravity — LONG-TERM ACCEPTANCE RATE(S): .35
EVALUATED BY: J.C. Moore — OTHER(S) PRESENT: Andy Watts Daniels
COMMENTS: ____

0013600