DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Scott Beattie
ADDRESS: _____
OWNER__ AGENT__ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____

LOCATION OF SITE: Lot 59 Beechwood II .1472 acres
WATER SUPPLY: On-site Well ___ Comun. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (1)(1) TEXTURE	(1)(2) STRUCTURE	(1)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1 Linear		0 to 8"	L	GR				.1942 Wetness Cond. - N/A
		8 to 24	C	ABK				.1943 Depth/.1956 Sapr. - N/A
	AD	24 to 36	CL	weak ABK				.1944 Restrictive Hori. - N/A
		36 to 48	Transition					.1948 Profile Class. - PS
								Profile LTAR - .3
2 Linear		0 to 8	L	GR				.1942 Wetness Cond. - N/A
		8 to 36	C	ABK				.1943 Depth/.1956 Sapr. - N/A
	AD	36 to 48	weak C	ABK				.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) yes OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .3 gal/sq'/day

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: John Craven

COMMENTS: _____

0029