4761230378

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 147886 PIN # 4761-33-1174.026 DATE 4-28-10

OWNER or APPLICANT BRAZOS DEV. PHONE: Business 704-535-4080 Home:

OWNER or APPLICANT ADDRESS PO BOX PENNER NC 28037

LOCATION / DIRECTIONS OSWALT AMITY, TR WHEATFIELD, TR EMMA MAE, TR LOGAN CROSSING

SUBDIVISION WHEATFIELD BLOCK / SECTION LOT # 26 LOT AREA .46 AC DESIGN FLOW 360 GPD L.T.A.R. .3

Septic Tank [redacted] Gallons: STB 1060 Date 4/23/2010 ☒ New System ☐ Repair ☐ Expansion System Type (II) III IV V VI

[redacted] 1060 GAL Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 6 Linear Feet 310'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth — ☒ GRAVITY ☐ PRESSURE

System Description: GRAVITY 25% REDUCTION

Repair System Description: LP- PANEL BLOCK

Maintenance Agreement Required ☐ YES ☒ NO INITIALLY

☒ Residence No. Bedrooms 3 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☒ Crawl Space ☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions 1) TANK & LINES MUST BE 10' FROM DOWNSIDE SLOPE OF BASEMENT & 15' FROM SIDES 2) MEET ALL OTHER REQUIRED SETBACKS

Comments / Conditions Used Quick 4 Filter in ST

INITIAL SITE SKETCH

SEE PLAN FROM ROLLANS SOIL & ENVIRONMENTAL SERVICES APPROVED BY ICHD

AS BUILT SKETCH

TANK LOCATION CHANGED BECAUSE DECK WAS MOVED

CHECKED TOP 4 LINES

CHECKED FRAME TANK

CHECKED SAND IN TANK HOLE 6"

MD CHECKED LINES 5 & 6

CHAMBERS PER LINE

TOP LINE 20 18 14 11

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 4-28-10

Improvement Permit by: REHS Date 4-28-10

Authorzation to Construct by: REHS Date 4-28-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Adam Garcia

Operation Permit by: REHS Date: 10/16/2010

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant