owes 60.00 10.00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 147439 PIN# 4761331124.032 4761-23-6687 DATE 4/24/08

OWNER OR APPLICANT Corinthian Builders Ltd. PHONE: Business 704400-1258 Home

ADDRESS PO Box 990 Denver NC 28037

LOCATION Hwy 21 N TR Oswalt Amity TR Wheatfield TL Emma Mae Dr. TR Logan Ridge on Left

SUBDIVISION Wheatfield BLOCK / SECTION 1 LOT 32 LOT AREA .51 ac SITE CLASS. ES DESIGN FLOW 360 L.T.A.R. .83

Septic Tank: 1000 Gallons: STB 55 Date 5/7/08
Pump Tank: Gallons: PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 900 Linear Feet 300'
No Lines 2@150' Trench Width 36" Max Trench Bottom Depth *24"

☑ New System ☐ Repair ☐ Expansion System Type: ☐ II ☐ III ☐ IV ☐ V ☐ VI
System Description: Gravity 25% Reduction
Repair System Description: same
Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 3 No. Persons No. Employees

Water Supply: ☑ Individual ☐ Public ☐ Community

Gravel Depth N/A ☑ Gravity ☐ Pressure ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Installer may want to centerfeed the 150' drainlines.

* Need final plat recorded & received before AC.

Comments/Conditions: Plans received essentially same as IP 9/2/08 A.C.

INITIAL SITE SKETCH

See plans by SPCC

Keep trenches 24" max depth

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 4-28-8, Installed by: Corinthian Builders

Improvement Permit by: Anthony Cohen II date 4/24/08 Operation Permit by: Wesley Sparkes date 10/3/08

Authorization to Construct by: Anthony Cohen II RS date 9/2/08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK