10,000 pd $575.00 10-20-08

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 147901 PIN# ~~4761 53 1124~~ 4761 23 6975 DATE 9/23/08

OWNER OR APPLICANT CORINTHIAN BLDRS LTD. PHONE: Business 704-799-6955 Home

ADDRESS PO BOX 3421 MOORESVILLE, NC. 28117

LOCATION QS - AMITY TR WHEATFIELD TR EMMANAE ON R CORNER AT LOGAN RIDGE

SUBDIVISION WHEATFIELD BLOCK / SECTION LOT 18 LOT AREA .69 SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .275

Septic Tank: 1000 Gallons; STB 786 Date 5/2/08
Pump Tank: 1000 Gallons; PT 32 Date 6/2/08
Pump Make: Goulds Model WE Cu 511 HH Serial No. 10/08
Nitrification Field: No Fields 1 Square Feet 981 Linear Feet 327
No Lines 4 Trench Width 3 Max Trench Bottom Depth 24"

[X] New System [ ] Repair [ ] Expansion System Type: I II (III) IV V VI
System Description: PM TO 25% REDUCTION
Repair System Description: SAME
Maintenance Agreement Required: [ ] Yes [X] No
Gravel Depth [ ] Gravity [X] Pressure [ ] Slab [ ] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

[X] House/Mod. Home No. Bedrooms 3
[ ] Mobile Home No. Persons
[ ] Business No. Employees
[ ] Other

Water Supply: [X] Individual [ ] Public [ ] Community

Comments/Conditions: FAST TRACK DESIGN, CALCULATIONS, AND SPECIFICATIONS BY J+EC CONCORD - 704-720-9405

* INSTALLATION DEPTH 24" - NO MORE *

Comments/Conditions:

INITIAL SITE SKETCH

(1) CONTRACTOR SHOULD HAVE ALL J+EC INFORMATION ON SITE WHILE WORKING

(2) NO CHANGES WITHOUT WRITTEN ICHD APPROVAL IN HAND

(3) MAXIMUM TRENCH DEPTH 24" - NO MORE ADDITIONAL SUITABLE COVER MAY BE REQUIRED

AS BUILT SKETCH

SEE ATTACHED ZONING PLAT

The location of the proposed SHED addition does not appear to impact the existing septic system.

**NOTE:

REHS

Date: 11-18-11

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [X] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X date 10-20-08 Installed by: Corinthian

Improvement Permit by: Wesley Sparks RS. date 9/23/08 Operation Permit by: date 4/7/09

Authorization to Construct by: Wesley Sparks RS. date 10/20/08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK