IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 147441 PIN # 4761239626 DATE July 23, 2010

OWNER or APPLICANT Brazo's Development PHONE: Business 704-201-6532 Home:

OWNER or APPLICANT ADDRESS P.O. Box 1159 Troutman NC 28166

LOCATION / DIRECTIONS Hwy 21 N TR Oswalt Amity TR Wheatfield TR Emma Mae Th Logan Ridge on Right

SUBDIVISION Wheatfield BLOCK / SECTION LOT # 34 LOT AREA .50 Ac. DESIGN FLOW 360 gpd L.T.A.R. .25 gpd/ft²

Septic Tank 1000 Gallons: STB 786 Date 3-27-10

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 6 Linear Feet 240

Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth sand ☒ GRAVITY ☐ PRESSURE

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: Gravity PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ Residence No. Bedrooms 3 ☐ Business No. Persons 6 ☐ Other No. Employees ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions 8/25/2010 Checked Panel lines & Adjusted Dist. box. Installer needs to reset tank El Check for fall from ST to Drainfield

OK 8/27/10

Comments / Conditions 63Ft of Supply line ~ 12inch fall

INITIAL SITE SKETCH

See Plan from Michael Athanas & Associates

Approved by ICHD

AS BUILT SKETCH

Installed Panel lines As Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 7-23-10

Improvement Permit by: Judy McNeill Date 7-23-10

Authorization to Construct by: Judy McNeill Date 7-23-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Adam

Operation Permit by: Date: 8/27/2010

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant