4761240185

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 147367 PIN # ~~4761 24 0196~~ (Lot 78) DATE September 14, 2010

OWNER or APPLICANT Brazos Development PHONE: Business Home:

OWNER or APPLICANT ADDRESS P.O. 1179 Troutman NC 28166

LOCATION / DIRECTIONS Hwy 21 N TR Oswalt Amity TR Wheatfield on left

SUBDIVISION Wheatfield BLOCK / SECTION LOT # 77&78 LOT AREA .92Ac. DESIGN FLOW 480gpd L.T.A.R. .3gpd/ft²

Septic Tank 1000 Gallons: STB 786 Date 10-5-10
Pump Tank Gallons: PT Date
Pump Make Model Serial #
Nitrification Field No Fields 1 No Lines 4 Linear Feet 400
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI
System Description: 2590 Reduction Gravity
Repair System Description: LP PPBPS
Maintenance Agreement Required ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons 8
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions
Well must be 100'+ from septic system
House must be plumbed to septic

Comments / Conditions 12/1/2010 Reviewed Floor plans in Compliance with original plan & permit

INITIAL SITE SKETCH

tank as shown or a pump will be needed for septic field.

See Plan from Michael Athanas & Associates Approved by ICHD

Divert drainage to property line as shown on site layout.

Fill ditch on property line between lot 77 & 78

AS BUILT SKETCH

Installed "Quick 4" essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date

Improvement Permit by: Cindy Melville RS Date 9-15-10

Authorization to Construct by: Date 12/1/10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Aaron C. Gurney

Operation Permit by: Date: 11/21/2011

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant