IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT — EXISTING SYSTEM INSPECTION

PERMIT# 147885 PIN# 4761 33 1124.011 DATE 7/2/08

OWNER OR APPLICANT CORINTHIAN BLDRS. LTD. PHONE: Business 704-400-1258

ADDRESS PO BOX 990 DENVER, NC, 28037

LOCATION QUALITY TR WHEATFIELD DR. 5th on R after Eagan Ct.

SUBDIVISION WHEATFIELD BLOCK / SECTION ____ LOT 11 LOT AREA 2.93 AC SITE CLASS PS DESIGN FLOW 4 BR 3

Septic Tank: 1500 Gallons: STB 530 Date 2-9-09
Pump Tank: 1500 Gallons: PT 480 Date 2-9-09
Pump Make: Gilbert Model WE0511H Serial No.
Nitrification Field: No Fields 1 Square Feet 1599 Linear Feet 533
No Lines 5 Trench Width 3' Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: PRESMAN. -25% REDUCTION
Repair System Description: SAME TYPE
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other Bedrooms 4 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: (1) SYSTEM DESIGN, LAYOUT, AND SPECIFICATIONS BY S+EC CONCORD, NC. PH 704-720-9405 (2) NO CHANGES WITHOUT WRITTEN PERMISSION OF ICHD.

Comments:/Conditions:

INITIAL SITE SKETCH

FAST TRACK DESIGN BY S+EC-CONCORD.

(1) HOUSE PLANS REQUIRED BEFORE AUTHORIZATION TO CONSTRUCT MAY BE ISSUED.

AS BUILT SKETCH

The proposed / existing DECK addition does not appear to impact the existing septic system.
**NOTE: ____ REHS
Date: 04-28-10
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Mike Sapp date 5/13/9
Improvement Permit by: Wesley Sparks R.S. date 5/13/09
Authorization to Construct by: Anthony Cohen Jr. R.S. date 5/13/09

Installed by: El Laso
Operation Permit by: Ramona date 7/24/09
Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK