pd $50.00 10-20-08 10.30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# ~~[illegible]~~ 197352 PIN# 4761 33 1124.059 4761-24-5408 DATE 6/

OWNER OR APPLICANT Countryside Estates Ltd PHONE: Business 704-400-1258 Home

ADDRESS PO Box 990 Denver NC 28037

LOCATION Off of Hwy 16 TR Wheatfield Jetton Road TR 2ND street Emmanuel Corner lot on (R)

SUBDIVISION Wheatfield BLOCK / SECTION 1 LOT 130 LOT AREA .51 SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 786 Date 9-1-12

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 900 Linear Feet 300

No Lines 5 Trench Width 3' Max Trench Bottom Depth 24"

X New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: ACCEPTED - 25% REDUCTION

Repair System Description: P-16" APPRS (STRAIGHT)

Maintenance Agreement Required: ☐ Yes ☒ No

X House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons No. Employees

Water Supply: X Individual ☐ Public ☐ Community

Gravel Depth No X Gravity ☐ Pressure ☐ Slab X Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Fast Track Spec + Design by S+EC Concord # 704-720-9405

Comments:/Conditions:

Installed in 5 lines @ 60FT ea. Top 4 lines Quick 4 last line 57' Flow

INITIAL SITE SKETCH

(1) Additional suitable cover material necessary to produce uniform 6" minimum cover per manufacturers' recomendations

(2) Repair system will also require additional suitable cover mb to all for uniform coverage.

24" MAXIMUM TRENCH DEPTH FOR THIS SYSTEM

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months X Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X date 10-24-08 Installed by: Adan Garcia

Improvement Permit by: Wesley Sparks RS. date 6/10/08 Operation Permit by: Mario Hill Dotson RS date 5/1/13

Authorization to Construct by: Whitney Mabrey 2-27-13 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK