IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 147447 PIN# 4761 33 1124 .036 4761-24-6182 DATE 6/11/08

OWNER OR APPLICANT CORINTHIAN HOMES PHONE: Business 704-400-1258 Home

ADDRESS PO BOX 990 DENVER, NC. 28037

LOCATION OSWALT AMITY TR WHEATFIELD TR EMMA MAE TO 5th LOT ON R.

SUBDIVISION WHEATFIELD BLOCK / SECTION 1 LOT 17 LOT AREA .46AC SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 55 Date 2/8/08
Pump Tank: Gallons: PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 900 Linear Feet 300
No Lines 4 Trench Width 3 Max Trench Bottom Depth 24

[X] New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: ACCEPTED - 25% REDUCTION
Repair System Description: LP - 16" PP BPS
Maintenance Agreement Required: ☐ Yes [X] No

[X] House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Persons
☐ Business No. Employees
☐ Other

Water Supply: [X] Individual ☐ Public ☐ Community

Gravel Depth N/A [X] Gravity ☐ Pressure ☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: FAST TRACK DESIGN + SPECS. BY S+EC, CONCORD 704-720-9405

Comments:/Conditions: 8/14/08 Drawings checked

INITIAL SITE SKETCH

(1) 24" MAXIMUM TRENCH BOTTOM -

(2) ADDITIONAL SUITABLE COVER MATERIAL WILL BE NEEDED TO ENSURE A UNIFORM 6" COVER OVER DRAINFIELD

(3) S/T LOCATION HAS BEEN CHANGED TO RIGHT REAR OF HOUSE - NOT BESIDE HOUSE

AS BUILT SKETCH

(4) House has been changed from original plan. Need new plan before OP is issued!

(5) Septic tank put in wrong location. Check set backs before OP is issued. Septic tank must be moved as shown on perm. pl.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months [X] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X date 6-11-08. Installed by: Corinthian

Improvement Permit by: Wesley Speaks RS date 6/11/08 Operation Permit by: Rahmmm date 9/15/08

Authorization to Construct by: J. Allen date 6-11-08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK