(Ad#350.co 03/07/12 MS) AM

IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☐ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 171148 PIN # 4761241238 DATE 3-6-2012

OWNER Troutman Farms of Carolina APPLICANT: Brazos Development PHONE: Home/Cell # 704 576-3887 Business # (704) 528-0021

SITE ADDRESS 120 Emma Mae Drive OWNER / APPLICANT ADDRESS P.O. Box 1159 Troutman, NC 28166

SITE DIRECTIONS US 21/Hwy 115 N TR Oswalt Amity TR Wheatfield Dr. TR Emma Mae Dr. on right.

SUBDIVISION Wheatfield BLOCK / SECTION 1 LOT # 15 & 16 Combined LOT AREA .918 Ac DESIGN FLOW 480gpd L.T.A.R. .3 Int/.225 Rep

Septic Tank 1000g Gallons: STB 786 Date 7-13-11
Pump Tank ____ Gallons: PT ____ Date ____
Pump Make ____ Model ____ Serial # ____
No. Nitrification Fields: 1 No. Lines 3 Linear Feet 400ft
Trench Width 36" Max. Trench Bottom Depth 36" Int. Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI
System Description: Gravity - 25% Reduction
Repair System Description: Gravity LPP PPBPS
Maintenance Agreement Required ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons ____
☐ Other No. Employees ____
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: Keep Septic System at least 10ft from pl
Split flow of Drainlines with "Flow Dividers" or similar device such as "Multi Port End Cap"

★★ This permit is the combination of Lots 15 & 16 Must have recorded plat of lots showing they are combined before AC

INITIAL SITE SKETCH

See plan from Michael Athanas & Assoc.
Approved by ICHD.

AS BUILT SKETCH

INSTALLED AS SHOWN ON SITE SKETCH
BA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT with plat valid without expiration.* ☒ *IMPROVEMENT PERMIT with plat valid without expiration.* site plan valid 60 mo. ☐ *AUTHORIZATION TO CONSTRUCT* valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: [signature] Date 3-6-12 Installed by: ADAN BA

IMPROVEMENT PERMIT by: [signature] REHS Date 3/6/2012 OPERATION PERMIT by: [signature] REHS Date 4-26-12

AUTHORIZATION TO CONSTRUCT by: [signature] REHS Date 3-14-12 Existing System Inspected by: ____ REHS Date ____

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant