IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 147453 PIN # 4710124 7603 DATE 4-22-10

OWNER or APPLICANT BRAZOS DEV. PHONE: Business 704-535-4080 Home:

OWNER or APPLICANT ADDRESS DENVER NC

LOCATION / DIRECTIONS OSWALT AMITY, TR WHEAT FIELD, TR EMMAMAE, TL LOGAN RIDGE, TR TANGLE RIVER

SUBDIVISION WHEATFIELD BLOCK / SECTION LOT # 59 LOT AREA .51AC DESIGN FLOW 360 GPD L.T.A.R. .3

Septic Tank 1000 Gallons: STB 186 Date 2-17-10
Pump Tank Gallons: P T Date
Pump Make Model Serial #
Nitrification Field No Fields 1 No Lines 5 Linear Feet 200'
Trench Width 24-36" Max. Trench Bottom Depth 36" Gravel Depth SAND

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI
System Description: GRAVITY PANEL BLOCK
Repair System Description: LP- PANEL BLOCK
Maintenance Agreement Required ☐ YES ☒ NO INITIALLY
☐ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply
☒ Private
☐ Public
☐ Community

Comments / Conditions 1) FOLLOW STATE RULES

Comments / Conditions

INITIAL SITE SKETCH

SEE PLAN FROM ROLLANS SOIL & ENVIRONMENTAL SERVICES APPROVED BY ICHD

AS BUILT SKETCH

9 PANELS PER DITCH
INSTALLED AS SHOWN

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date

Improvement Permit by: REHS Date 4-22-10

Authorzation to Construct by: REHS Date 4-22-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: ADAN

Operation Permit by: REHS Date: 6-8-10

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant