
Not A Survey



PROJECT NO.
#S-1862
PROJECT MGR.
BF
DRAWN BY
E.B.
FIELD WORK
E.B.
SCALE
1" = 40
FILE
Y:\jobs\S-1862

Soil & Environmental Consultants, PA
238 LaPhilip Court, Suite C • Concord, North Carolina 28025 • Phone (704)720-8405 • Fax (704) 720-8406

S&EC

Wheatfield lot 87
Custom Builders
- Wheatfield lot 87 -
IREDELL COUNTY, NORTH CAROLINA
DEC 2007

SHEET TITLE:
Preliminary Site Plan
SKETCH MAP

SHEET
1 OF 1

DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: _____
COUNTY: Iredell_____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Corinthian Builders _____
DATE 12/12/2007 _____ APPLICATION
ADDRESS: Oswalt Amity Rd._____
PROPOSED FACILITY: 3 bedroom Home PROPOSED DESIGN FLOW (.1949): 360 gpd___ DATE EVALUATED: 12/10/2007____
LOCATION OF SITE: Lot 87_____ PROPERTY SIZE: _____
WATER SUPPLY: Private Public ΞWell Spring Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: Auger Boring (X) Pit Cut TYPE OF WASTEWATER: ΞSewage Industrial Process Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2-5%	0-12 12-60 60-67	W F GR/ SL W F SBK / C M M SBK/ CL	NS, NP,FR / NEXP SS, SP,FR/ SEXP SS, SP, FR/ SEXP	>67"	>67"	NA	S	PS .325
2	L 2-5%	0-11 11-39 39-60	WFGR / SCL MMSBK / C WFSBK / CL	NS NP FR / NEXP SS SP FI / SEXP SS SP FR / SEXP	>60	>60	NA	S	PS .325
3	4010	0-8 8-34 34-44 44-51	gr SL MMSBK/C M-FSBK C+SAP WK-FSBK CL+SAP	DFR FR SS SP SEXP FR SS SP FR SS SP					.3

LICENSED SOIL SCIENTIST
JAMES WENDELL OVERBY
1216
STATE OF NORTH CAROLINA

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR	0.325	0.325

OTHER FACTORS (.1946): _____PS_____
SITE CLASSIFICATION (.1948): ___PS_____
EVALUATED BY: _____Fulton Bailey_____
OTHER(S) PRESENT: _____

COMMENTS: Approved .3 LTAR ICHD gm

LEGEND
use the following standard abbreviations