IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

P. Fleet 5-27

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 147361 PIN # 4761 24 8289 DATE May 19, 2011

OWNER or APPLICANT Brazos Dev. PHONE: Business 704-528-9411 Home:

OWNER or APPLICANT ADDRESS P.O. 1179 Troutman NC 28166

LOCATION / DIRECTIONS Hwy 21 N TR Ostwalt Amity TR Wheatfield TR Emma Mae on left

SUBDIVISION Wheatfield BLOCK / SECTION LOT # 72 LOT AREA .46 Ac DESIGN FLOW 360gpd L.T.A.R. .275 gpd/ft²

Septic Tank 1000 Gallons: STB 6-12-11 Date 7/86

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 5 Linear Feet 345

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: 25% Reduction gravity

Repair System Description: LPPPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions Install at 36"

Comments / Conditions

INITIAL SITE SKETCH

See Plan from Michael Athanas & Assoc. Approved by ECHD

QUICK 4T INSTALLED AS SHOWN

END CAP DIS.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Brazos Dev. Date 5/27/11

Improvement Permit by: Judy Mellwell REHS Date 5-19-11

Authorization to Construct by: Judy Mellwell REHS Date 5-27-11

Installed by:

Operation Permit by: ADAM BEAVERS REHS Date: 8-2-11

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant