4761 24 8348

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 147486 PIN# 4761331124.073 DATE 2-6-08

OWNER OR APPLICANT Corinthian Builders Ltd PHONE: Business 704-400-1258 Home

ADDRESS P.O. Box 990 Denver NC 28037

LOCATION Hwy 21 N TR Oswalt Amity TR Wheatfield TR Emma Mae on left

SUBDIVISION Wheatfield BLOCK / SECTION 1 LOT 73 LOT AREA .46 Ac SITE CLASS. PS DESIGN FLOW 360gpd L.T.A.R. .275 gpd/ft²

Septic Tank: 1000 Gallons: STB 785 Date 1/8/08

Pump Tank: 1000 Gallons: PT 32 Date 9/5/07

Pump Make Gould's Model VEO5112A Serial No.

Nitrification Field: No Fields 1 Square Feet 6600 Linear Feet 220

No Lines 6 Trench Width 36" * Max Trench Bottom Depth 30" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons 6 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: * per plan specs

In-line filter in pump tank required

Comments/Conditions:

Tanks & Drainfield checked 8/14/08

INITIAL SITE SKETCH

See plan from S&EC

AS BUILT SKETCH

Maintenance Contract Rec'd 9/2/08

Pressure & Valvebox & Electrical checked 9/4/08

System Installed as shown on plan A.C.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 3/4/08 Installed by: Corinthian

Improvement Permit by: Judy Melville date 8-20-08 Operation Permit by: Anthony Cohen J.D.S. date 9/4/08

Authorization to Construct by: Judy Melville date 5-22-08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK