IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 147402 PIN # 4761 24 8995 DATE December 30, 2011

OWNER Brazos Development II APPLICANT: same PHONE: Home/Cell # 704-201-6532 Business #

SITE ADDRESS 177 Wheatfield Dr, Statesville OWNER / APPLICANT ADDRESS PO Box 1159 Troutman 28166

SITE DIRECTIONS Hwy 21 N TR Oswalt Amity TR Wheatfield on left 2nd from end

SUBDIVISION Wheatfield BLOCK / SECTION 1 LOT # 88 LOT AREA .54 Ac DESIGN FLOW 360 gpd L.T.A.R. .275 gpd/Ft²

Septic Tank 1000 Gallons: STB 786 Date 1-16-11

Pump Tank Gallons: P T Date

Pump Make Model Serial #

No. Nitrification Fields: 1 No. Lines 4 Linear Feet 328

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: 25% Reduction Gravity

Repair System Description: LP 25% Reduction pump

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

Keep plumbing to ST shallow enough to achieve gravity system

INITIAL SITE SKETCH

See Plan from Michael Athanas & Assoc.

Approved by ICHD

AS BUILT SKETCH

Note: ST is 5FT from Deck & N 7FT to HSE

Used Quick 4 end feed no dist box, no drop boxes.

Installed essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☒ ***IMPROVEMENT PERMIT*** *with ~~plat valid without expiration.~~ site plan valid 60 mo.* ☐ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Date

IMPROVEMENT PERMIT by: Judy Melville REHS Date 12-30-11

AUTHORIZATION TO CONSTRUCT by: Judy Melville REHS Date 12-30-11

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

Installed by: Adan

OPERATION PERMIT by: Marvin Wilson RS REHS Date 2/23/2012

Existing System Inspected by: REHS Date

White Copy -- Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant