DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #
COUN 1 /

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: James Aller APPLICANT: James Aller
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/23/01
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	4% Linear	0-14	scl	fr	SEX				PS .3
		14-22	cl m sbk	fr/fi	SEX				
		22-36	sl/sap						
		36-48	sap						
2	4% Linear	0-22	scl	fr	SEX				PS .3
		22-26	cl m sbk	fr/fi	SEX				
		26-49	sl/sap	fr	SEX				
3	7% Linear	0-12	scl	fr	SEX				PS .3
		12-20	cl m sbk	fr/fi	SEX				
		20-38	cl/sap w sbk	fr					
		38-49	sap	fr	LEX				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conv	25% Red Gravity
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____