12945.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RICHARD TODD BROWN DATE 6-24-91 PERMIT NO. SB-2-A-26

PHONE: Business _____ Home _____

LOCATION Bethesda Rd. & Hy Hwy 70 E - go approx. 3.5 mi b/o T.R. into dev. T.R. on 1st street - 3rd lot on left.

S. R. No. _____

SUBDIVISION NAME WOODHAVEN ESTATES LOT NO. 26 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Appears Suitable.
Percolation Rate 4 min./1 in. ff.
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none observed.

Lot Area 2.5 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Lineal Ft. 300
Depth of Stone in Lines 12
Water Supply: Individual (✓)
Public ( )

Installed by Spivey Septic Tank George Kirpatrick

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-24-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold