HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Darrell Atkins OWNER: _____ AGENT: _____ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: Single Family
PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	1941 (a)(2) STRUCTURE	1941 (a)(3) MINEROLOGY		
1	linear 2 to 4%	0 to 4"	b	GR		.1942 WETNESS CONDITION	N/A
		4 to 36	C	ABK	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 48	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
2	linear 2 to 4%	0 to 5"	b	GR		1942 WETNESS CONDITION	mottling 18 to 24"
		5 to 18"	C	ABK	1:1	.1943/.1956 SAPROLITE	N/A
		18+	C	ABK	2:1	.1944 RESTRICTIVE HORIZON	mottling 18 to 24
						.1948 PROFILE CLASSIFICATION	U
						PROFILE LTAR	<.1
3	linear 2 to 4%	0 to 5	b	GR		1942 WETNESS CONDITION	N/A
		5 to 24	C	ABK	1:1	.1943/.1956 SAPROLITE	N/A
		24 to 48	C	weak ABK	1:1	1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) _____ SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE Shallow Conv. Gravity
EVALUATED BY: R.C. Moore OTHER(S) PRESENT: Johnny Craver
COMMENTS: _____

DRAFT