HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Phillip Bowles OWNER: __ AGENT: __ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 7-1-94
PROPOSED FACILITY: Single Family
PROPERTY SIZE: Owner 3 bedroom
LOCATION OF SITE: Lot 21 Beechwood II
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	linear slope 10%	0 to 6	L	GR		.1942 WETNESS CONDITION - N/A
		6 to 36	C	SBK	L.I	.1943/.1956 SAPROLITE - N/A
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	linear slope 10%	0 to 7	L	GR		.1942 WETNESS CONDITION - N/A
		7 to 36	C	SBK	L.I	.1943/.1956 SAPROLITE - N/A
		36 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3	linear slope 12%	0 to 7	L	GR		.1942 WETNESS CONDITION - N/A
		7 to 42	C	SBK	L.I	.1943/.1956 SAPROLITE - N/A
		42 to 48	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) _____ SYSTEM TYPE Conv. lines
EVALUATED BY: _____ OTHER(S) PRESENT: Johnny Craver
COMMENTS: _____

DRAFT