DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ____ OF ____

PROPERTY I.D.#: _____

DATE: _____

COUNTY: _____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Scott Beattie OWNER ___ AGENT: ___ PHONE: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED _____

_____ PROPOSED FACILITY: _____

_____ PROPERTY SIZE: _____

LOCATION OF SITE: Lot 76 Beechwood

WATER SUPPLY: On-site Well / Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring / Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1 linear 590		0 to 8	L	GR				.1942 Wetness Cond. - N/A
		8 to 36	C	ABK	1:1			.1943 Depth/.1956 Sapr. - N/A
		36 to 48	C	weak ABK	1:1			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
2 linear 590		0 to 8	L	GR				.1942 Wetness Cond. - N/A
		8 to 36	C	ABK	1:1			.1943 Depth/.1956 Sapr. - N/A
		36 to 48	C	weak ABK	1:1			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945): yes OTHER FACTORS (.1946) _____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE conv. Gravity LONG-TERMACCEPTANCE RATE(S) .3 gal/sq'/day

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: John Craver

COMMENTS: _____