IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Mike Tuberville DATE 7-2-92 PERMIT NO. _____

PHONE: Business 663 0300 Home 892 9119

LOCATION 70 E TR Bethesda Rd TR into Beechwood 4th Home on Rt mh S.R. No. _____

SUBDIVISION NAME Counting Corner mh LOT NO. _____ SECTION OR BLOCK NO. _____

before 2nd Elec. Transformer

House ☐ Mobile Home ☑ Business ☐ Other Repair

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit Yes ☐ No ☐

Auto. Dishwasher Yes ☐ No ☐

Auto. Wash. Machine Yes ☐ No ☐

Lot Area _____

Soil Characteristics Clayey


Application Rate 1 4

Topography 2 to 6%

Depth to Water Table 10'+

Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank Ex. Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 450 Linear Ft. 150

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Bobby Mayhew Carpenter

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

Step down

IMPROVEMENT PERMIT BY J. C. Moore

COMMENTS _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-2-92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold