DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 12-1-99
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: lot 6 Deer Valley PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	gr bar sl sol fr		26"+			LPP soil type 2 thin pet	.15-.1
		6-30	m-lgsbk rbk cl fr ss sp						
		30-51	gl gl shw sc fr ss sp mpd						
2		0-8	gr fsm sl sol fr		55-75" fluctuation	common mica	common mica		15 .15-.3 @ ≤ 35"
		8-37	SAB rbk cl fr ss			extremely ch 3-6"			
		37+	mk sab shw rbk cl fr						
3		0-5	MK SAB fsm sl fr sss sp		few common mica sp				15 .3+
		5-53	BC m-lgsbk rbk cl/c fr fss sp						
	1-14-2000	0-12	SAB MC	fr ss p					25 .3
		12-48	R, grch	few mica p/ss w fr ss p					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ailable Space (.1945)		
stem Type(s)		
e LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____