DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: Nov 29, '99
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 8 Deer Valley PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☒ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-7	brn sdl	frfssp					PS .3 @ ≤ 324
		7-32	SAB Rd cl	frsp					
		32-53	wt sab/ms yp	cl/l comm mfsp/pl mfss fpssp					
2		0-8	gr brn sl/sdl fr						PS .3 @ ≤ 390
		8-37	SAB Rd cl	frsp					
		37-53	wt sab/ms yp cl	frssp Com mfsp fpssp Separating w/depth					
3		0-12	gr-w ksab brn sl/sdl fr						PS .3
		12-48	SAB Rd cl	frsp-ssp predominately sdl	poor/jelly wk on PS & part				
		0-14	S abr g	frsp					
		14-48	W sab pyr cl	Com l-s mfsp/mssp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ailable Space (.1945)		
stem Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____