DC 2122 881 CI 704-5823

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 19782 PIN# 4761-49-3220 3137 DATE 9-8-08

OWNER OR APPLICANT ABMS Development ENC PHONE: Business 704-664-7029 Home

ADDRESS 111-B Raceway Drive Mooresville NC 28117

LOCATION 70E to Bethlehem Rd Wallace Drive on right

SUBDIVISION North Lake BLOCK / SECTION LOT 2 LOT AREA 1.53 ACRE SITE CLASS. RS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons: STB 791 Date 8-20-08

Pump Tank: 1000 Gallons: PT 243 Date 7-11-08

Pump Make: Gouds Model WEW 3/2HW Serial No. 5004853

Nitrification Field: No Fields Square Feet 1920 Linear Feet 320

No Lines 5 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A Gravity Pressure

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 50% Low Pres

Repair System Description: 50% Low Pres

Maintenance Agreement Required: ☐ Yes ☐ No

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☑ Public ☐ Community

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Un-Held, 50% reduction System Using 73 PPBS Panels - Lo Pres. Distribution Box. Contract shall be executed between the owner & management

Comments:/Conditions: Poly for Fittings & Risers Install as Contain Maintain all setbacks

INITIAL SITE SKETCH

See Attached "Fast Track" Site Plan Prepared by: Rollins Soil and Environmental Services.

AS BUILT SKETCH

Ft 10' off marked R/L. System Installed as Passed

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 9-8-08 Installed by: Court Dawson & Cobb INC

Improvement Permit by: [signature] date 9-8-08 Operation Permit by: [signature] date 10-13-08

Authorization to Construct by: [signature] date 9-8-08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK