IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# REPAIR PIN# 4761-54-2584 DATE 10/13/06

OWNER OR APPLICANT JEAN MYERS PHONE: Business 336-725-2393 Home 336-416-6737 336-416-6747

ADDRESS 125 KIRKLEIGH COURT KING, NC 27021

LOCATION HWY 21 NORTH, (R) OSTWALT AMITY RD., PROPERTY ON RIGHT @ BOX # 1142,

SUBDIVISION DEER VALLEY BLOCK / SECTION ____ LOT 46 LOT AREA 0.99 Ac. SITE CLASS. REPAIR DESIGN FLOW 360 GPD L.T.A.R. REPAIR - (0.30) ORIGINAL PERMIT

Septic Tank: 1,000 Gallons: STB 1012 Date 03/24/01
Pump Tank: 1,000 Gallons: PT 17 Date 11/12/00
Pump Make: GOULDS Model WE0311M Serial No. H0669398
Nitrification Field: No Fields 1 Square Feet 900 Linear Feet 300
No Lines 3@100' Trench Width 36" Max Trench Bottom Depth 36"

☐ New System ☒ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: ____
Repair System Description: REPLACE PUMP + COMPONENTS
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Persons ____
☐ Business No. Employees ____
☐ Other ____

Water Supply: ☒ Individual WELL ☐ Public ☐ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions:
SYSTEM REPAIRED ACCORDING TO INITIAL SITE SKETCH

INITIAL SITE SKETCH

1. REPLACE PUMP, IF NEEDED.
2. REPLACE PUMP CONTROLS/ALARM FLOATS
3. RE-WIRE PUMP ELECTRICAL + SEAL PIPE TO N/X BOX.
4. VERIFY ALARM FUNCTIONS AND SEPERATE PUMP/ALAM CIRCUITS.
5. SET PRESSURE + CHECK FOR SUPPLY LINE LEAKS.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Dennis Gallehr date Nov 8, 06 Installed by: A-1 BACKHOE

Improvement Permit by: [signature] date 10/13/06 Operation Permit by: STEVE HEDRICK date 11-8-06

Authorization to Construct by: [signature] date 10/13/06 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK