SHEET ____ OF ____

DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Robert Dean Gallihes OWNER__AGENT:__PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____

LOCATION OF SITE: _____
WATER SUPPLY: On-site Well____Comm. Well____Public____Other_____EVAL. METHOD: Auger Boring__Pit__Cut__

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 24	C	ABK	1:1			.1943 Depth/.1956 Sapr. - 36"
	linear	24 to 36	clay saprolite					.1944 Restrictive Hori. - N/A
	H90	36	saprolite					.1948 Profile Class. - PS
								Profile LTAR - .3
2		0	No Top Soil					.1942 Wetness Cond. - N/A
	linear	0 to 24	C	ABK	1:1			.1943 Depth/.1956 Sapr. - 36"
		24 to 36	clay saprolite					.1944 Restrictive Hori. - N/A
	H90	36	saprolite					.1948 Profile Class. - PS
								Profile LTAR - .3
3		0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 24	C	ABK	1:1			.1943 Depth/.1956 Sapr. - 36"
	linear	24 to 36	clay saprolite					.1944 Restrictive Hori. - N/A
	H90		saprolite					.1948 Profile Class. - PS
								Profile LTAR - .3
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) yes OTHER FACTORS (.1946) _____ SITECLASSIFICATION (.1948) ~~CONV~~ PS

SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .3

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Robert Dean Gallihes

COMMENTS: _____

0 0 0 6 5 5