DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: DAVIDSON

SWART #10

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: TERESA NEWTON APPLICANT: SAME
ADDRESS: 525 SHEPHERDS RD, THOMASVILLE 28166 APPLICATION DATE: 8-29-02 DATE EVALUATED: 9-23-02
PROPOSED FACILITY: 3BR HOME PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~1 ACRE
LOCATION OF SITE: WILLIAM C. SWART # 10 PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	H 4%	0-12	GR SL	VFR SE/P					PS 0.25
		12-20	SBK SC	FR SE/P					
		20-32	MMBK C	FI SS/SP SE/P					
		32-48	SBK SC	FR SE/P					
2	L 8%	0-14	GR SL	VFR SE/P					PS 0.3
		14-36	ABK C	FR SE/P					
		36-48	ABK C (SAP MIX) (BLACK MOTTLES)	FR SE/P					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HADDOCK
OTHER(S) PRESENT: PATRICK MITCHELL, TERESA NEWTON, TRACY GOODRUM