IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Michael Brewer DATE July 6, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70E, T.R. on Rd #2318 - cross creek, T.L. on Rd #2358 TR on 2nd dirt Rd, house on left after curve S. R. No. _____


SUBDIVISION NAME Lloyd Acres LOT NO. 11 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ½ acre

Character & Porosity of Soil Clay
Percolation Rate good
Topography 6-10% slope to front
Depth to Water Table _____
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

RTIFICATE OF COMPLETION BY Andrew L. Carey, David R. Henson DATE 7/6/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold