DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: HUGH MOOSE APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: LOT 5 BEVIS RD PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	6% LSS	0-3"	SL, wk, gr	fr, ns, np, ms/p		>48"			PS .25
		3-20"	CL, med, sbk	fr, ss, sp, scp					
		20-48"	BLACK SAPROLITE MIX CL, med, sbk	fr, s, p, scp					
2	6% LSS	0-3"	SL, wk, gr	fr ns np ms/p		>48"			PS .25
		3-22"	CL, med, sbk	fr ss sp scp					
		22-48"	BLACK SAPROLITE CL, med, sbk	fr s p scp					
3	3% C	0-3	scl, wk, gr	fr, ns, np, ms/p		>48"			PS .3
		3-32"	C, med, sbk	fr, ss, sp, scp					
		32-48"	loamy ssp	fr, ns, np, ms/p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Availble Space (.1945)	YES	YES
System Type(s)	.25	.25 or .3
Site LTAR	Gen 75%/600	LP PAVER

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COLE
OTHER(S) PRESENT: _____