DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____ - ____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Linda Greer APPLICATION DATE 2-5-01
ADDRESS: Poolesville, MD DATE EVALUATED: 1/15/01
PROPOSED FACILITY: 3 BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 8.31 Ac.
LOCATION OF SITE: Hwy 28 to Rt Barnesville Rd. (R) on Fox Hunt Dr. End PROPERTY RECORDED: YES
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	14% Linear	0-6"	SL gr	VFr NS NP VFp					PS .4
		6-30"	Scl vgbk	fr SS SP Sep					
		30-42"	SL gr	fr NS NP					
		42-	Rock						
2	13% Linear	0-7"	SL gr	VFr NS NP VFp					PS .4
		7-31"	Scl vgbk	VFr SS SP SEp					
		31-41"	SL gr	VFr NS NP SEp					
3	12% Linear	0-16	SL gr	VFr NS NP VFp					PS .35
		16-32	Scl vgbk	Fr SS SP SEp					
		32 41"	SL gr	VFr NS NP SEp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Red. Trench	25% Red. Trench
Site LTAR	.4	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Lehman
OTHER(S) PRESENT: _____

COMMENTS: _____