DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 4762-21-9543
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: FLEETWOODS OF TROUTMAN APPLICANT: TERESA NEWTON
ADDRESS: 1090 CHAR/HWY, TROUTMAN APPLICATION DATE: 8-20-02 DATE EVALUATED: 9-9-02
PROPOSED FACILITY: 3BED D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.67 ACRE
LOCATION OF SITE: FAIRWINDS (LOT #31) PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 20%	0-18	SBK CL	FR SEXP					PS 0.3
		18-38	SBK SAPROLITE MIX W/CL	FR SEXP					
		38-48	SBK SAPROLITE CL MIX	VFR SEXP					
2	L 22%	0-16	SBK CL	FR SEXP					PS 0.3
		16-40	SBK SAP MIX W/CL	FR SEXP					
		40-48	WSBK SAP MIX CL	VFR SEXP					
3	PIT L 22%	0-16	SBK CL	FR SEXP					PS 0.3
		16-38	SBK SAP MIX CL	FR SEXP					
		38-48	SAPROLITE						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	T	1
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. WISNIEWSKI
OTHER(S) PRESENT: DENNIS GALLIHER / TERESA NEWTON