REDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 — MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 102956 PIN# 4762-30-1914 DATE Nov 5, 01

OWNER OR CONTRACTOR ~~Bethel Rentals LLC~~ Darrin/Shonna Freeland PHONE: Business _____ Home _____

ADDRESS P.O. Box 1732, Lincolnton, N.C. 28092

LOCATION 70 East TR Bethesda TR Robins Hill Lane on left

SUBDIVISION Fairways BLOCK / SECTION _____ LOT 18 LOT AREA .85± SITE CLASS PS DESIGN FLOW 360gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 794 Date 10-9-01

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

[X] New System [ ] Repair System Type: I II III IV V

System Description: Gravity conventional

Repair System Description: same

Maintenance Agreement Required: [ ] Yes [X] No

[X] House/Mod Home No. Bedrooms 3

[ ] Mobile Home No. Bathrooms 2

[ ] Business No. Employees _____

[ ] Other _____

[ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Water Supply: [X] Individual [ ] Public [ ] Community

Comments/Conditions

Comments/Conditions -Septic Tank Riser Installed
-Zabel & filter Installed
-Lines Okay -BL
K.S. gave prior approval to move driveway

INITIAL SITE SKETCH

1"=50'

230.47'

Repair Area

Drop Boxes

DRIVEWAY

House Site 30'

60'

100'

60'

25'

Rt Robins Hill Lane

WELL

249.19'

AS BUILT SKETCH

First Hole

at Stream

Per Initial Site Sketch

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date _____

Improvement Permit by: _____ date 11-5-01

Authorization to Construct by: _____ date 11/19/01

Installed by: Marty Tucker

Operation Permit by: _____ date 12-7-01

Existing System Inspection by: _____ date _____