DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 103533
COUNTY: 4762-31-2512

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: FLEETWOOD HOMES APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: FAIR WIND LOT 29 PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
TOPSOIL SCRAPED OFF

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	12% SS	0-6"	c med sbk	fr, ss sp scp					PS .35
		6-48"	cl loamy sap mix	fr ss sp scp					
2	12% SS	0-6"	c, med, sbk	fr ss sp scp					PS .35
		6-48"	cl loamy sap mix	fr ss sp scp					
3	8% LSS	0-3"	scl, wk, gr	fr ss sp scp					PS .3
		3-48"	c, med, sbk	fr, ss, sp, scp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	CONV GRAV	PUMP/LPP/LPD
Site LTAR	.35	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: LONNIE COOK
OTHER(S) PRESENT: _____