VISION OF ENVIRONMENTAL HEALTH:
I-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Howard Wagner APPLICANT: _____
DDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 8/1/2000
OPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
CATION OF SITE: _____ PROPERTY RECORDED: _____
ATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
ALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
PE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
A1-5	0-48"	Fill Dirt						V
A1-6	0-10"	Fill Dirt						
	10-24	10YR 4/1 Red Cl w/SBK						
	24-36	10YR 5/6 SCL w/ Inc		Lots of Chroma 2 Mottles				U
8/15/00 A1-7 Adjacent Lot	0-6"	Brn SCL/CL						
	6-24"	Brn to Red/Brn C m SBK to massive S,P,SE-E						V
		~23" Few Chroma 2 mottles						
	24"	Galade Grey Clay						
A1-8 & 9		Same as A1-7						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ilable Space (.1945)		
tem Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____