330 A-1

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 24972 DATE 9-23-96 TAX MAP NO. 5J-4-A-29 Watershed: ☐ Yes ☑ No

OWNER OR CONTRACTOR Charles Steven Hurst PHONE: Business Home 704 872 4739

ADDRESS 132 Hurst Dr. Statesville N.C.

LOCATION 70E TR Bethesda TL cornflower Rt Pine Tree TR log Cabin 7th lot Rt

SUBDIVISION J.L. Hope DIVISION BLOCK / SECTION LOT 21 LOT AREA 6.6 acres SITE CLASS. PS DESIGN FLOW L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1012 Date 10-26-96

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 Trench Width 36" Max Trench Bottom Depth 24" Gravel Depth 12"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Conv. Gravity

Repair System Description: Pump to Conv.

Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home ☑ Mobile Home ☐ Business ☐ Other


No. Bedrooms 3 No. Bathrooms 2 No. Employees

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing


Water Supply: ☑ Individual ☐ Community ☐ Public

Well Next door

Comments:



Comments:



mobile Home & well were not on site at time of this inspection

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system.

Signed: X Charles Steven Hurst

Improvement Permit by: L.C. moore date 9-23-96

Authorization to cover Existing System Inspection by: L.C. moore date 9-23-96

Installed by: A-1 Backhoe

Certificate of Completion by: date

Operation Permit by: L.C. moore date 2-20-97

HEALTH DEPT COPY WHITE INSPECTION COPY (FINAL) GREEN OWNER COPY (FINAL) YELLOW INSPECTION COPY (INITIAL) PINK OWNER'S PERMIT COPY GOLD

Authorization to cover Expires 60 mos from issue