DIVISION OF ENVIRONMENTAL HEALTH:
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Denell Hill APPLICANT: _____
ADDRESS: 420 Towell St. Mount APPLICATION DATE: 5/19/00 DATE EVALUATED: 6/10/00
PROPOSED FACILITY: 3BD w BSMT PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~9.19 AC
LOCATION OF SITE: Go. Amity TL Bethesda Rd TR Hickory Nut Rd TR PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other Driveway X creek to first grave/road on (L)
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 3%	0-5	sbk / cl	FI / S-NP / 1:1					
		6-15	wk sbk / C	FI / S-SP / 1:1					
		16-35	sbk / sc /	FR / NS-NP					
		35-52	GR / sl SAP.	VFR / NS-NP		S	PS	NA	.3
2	LS(T)	0-2	wk / cl						
		3-17	wk sbk / C	FI / S-SP					
		18-31	sbk / sc /	FR / SS-NP	PS				
		32-50	GR / S / SAP	VFR / SS-NP	PS	S	PS	NA	.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	PM → CONV	SAME
Site LTAR	.3	.3

OTHER FACTORS (.1946): Basement
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: Sparks
OTHER(S) PRESENT: D Hill, Jeff Lewis