IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James V. Rackley DATE 4/10/80 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E., T.R. at Wayside Groc., Then T.L. on 2360, approx 1 mile T.R. on 2508, ¼ mile on RT

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 2.11 Acres

Character & Porosity of Soil Aggahig Clay
Percolation Rate 120 min/inch
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY J. C. M.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew L. Causey + R W Johnson RS DATE 4/10/80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold