IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Builders Carl E. Mease DATE 10-29-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Pine Tree Farm 77 Rd. # 2360

_____ S. R. No. _____


SUBDIVISION NAME Pine Tree Farm LOT NO. 38 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	L MBZ
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	1 inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	level
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25 +
			Rock or other impervious formations	none

Lot Area 240 X 240 - 1 ACRE



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Hope Bros Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 10/29/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold