IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. C. Taylor DATE 5-26-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Highway 70 E to Wayside - TR on Rd 2359 - Thru TR on Rd 2360 - Development on Rt approx 3/4 mile

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. 92-93 SECTION OR BLOCK NO. Old Fairgrounds Farm

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2 acre


Character & Porosity of Soil Cecil clay

Percolation Rate Good

Topography Slight slope to Lake

Depth to Water Table 4ft

Rock or other impervious formations none



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Kenneth Chaffin

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 7 Jun 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold