DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:_____

DATE:_____

COUNTY:_____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Richard Hill

ADDRESS:_____

OWNER___AGENT:___PHONE:_____

APPLICATION DATE:_____ DATE EVALUATED_____

PROPOSED FACILITY:_____

PROPERTY SIZE:_____

LOCATION OF SITE:_____

WATER SUPPLY: On-site Well____ Comm. Well____ Public____ Other_____ EVAL. METHOD: Auger Boring____ Pit____ Cut____

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0to4	L	GR				.1942 Wetness Cond. - N/A
		4to24	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
		24to48	CL	weak SBK	1:1			.1944 Restrictive Hori. - N/A
	N 90							.1948 Profile Class. - PS
								Profile LTAR - .3
2		0to4	L	GR				.1942 Wetness Cond. - N/A
		4to24	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
		24to48	CL	weak SBK	1:1			.1944 Restrictive Hori. - N/A
	N 90							.1948 Profile Class. - PS
								Profile LTAR - .3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) YES OTHER FACTORS (.1946)_____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE_____ LONG-TERMACCEPTANCE RATE(S) .3

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Mrs Richard Hill

COMMENTS:_____