HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Tony Whitaker OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 10-21-93
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	Ridge 10%	0 to 4	L	GR		.1942 WETNES CONDITION - N/A
		4 to 24	C	ABK	1:1	.1943/.1956 SAPROLITE - 36 to 48" Trans.
		24 to 36	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - None
		36 to 48	Transition			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	Linear 10%	0 to 12	L	GR	1:1	.1942 WETNES CONDITION - (Chroma 3/4 8"
		12 to 36	C	ABK	1:1	.1943/.1956 SAPROLITE - BC 48"
		36 to 48	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON - none
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .28
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: RC Moore OTHER(S) PRESENT: No others Present
COMMENTS:

DRAFT