IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thad Ray McCoy DATE June 21, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70E., T.R. at Wayside Store on Rt# 2360, go 4 mls and T.L. on 2360, T.R. on 2nd dirt Rd, house on left S. R. No. _____

SUBDIVISION NAME Pine Tree Farms LOT NO. 61 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____ Future House

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 100 X 431


Character & Porosity of Soil Cecil Clay

Percolation Rate none

Topography slight slope to rear

Depth to Water Table ok

Rock or other impervious formations none observed



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2 (additional)
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey (Jim Lackey)

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Lacey DATE 6/21/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold