10145

IREDELL COUNTY HEALTH DEPARTMENT

35802

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Lapish DATE 1-17-90 PERMIT NO. SJ-4-A-90

PHONE: Business _____ Home _____

LOCATION 70 E TR Bethesda TL Cornflower 2nd Rt TR 1st lot on Rt

SUBDIVISION NAME Pine Tree Farms LOT NO. 4 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 105' X 210'

Character & Porosity of Soil Clayey

Percolation Rate 3

Topography 2 to 12%

Depth to Water Table 10'+


Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing ___✓___ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by Wayne Potts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: landscape so that surface water Will not stand over Tank & Drainlines

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 1-12-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold