IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Buddy Lowe DATE 8-30-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E. TR on Rt 2360 at Wayside Bus. to Pine Tree Farm 1st Division - 2nd St. S. R. No. _____


SUBDIVISION NAME Pine Tree Farm LOT NO. 71 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	med
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6ft
			Rock or other impervious formations	none

Lot Area 2.68



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Harry Lee

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Ford DATE 9/30/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold