IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jeff Lewis - R L Marlow DATE 2-23-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E. TR on Rd 2357 - Then Rt on Rd #2356 - 6th dwl 1/4 Mile House on Rt. S. R. No. 2356

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 4½ Acres


Character & Porosity of Soil CmB2

Percolation Rate sat - Lewis

Topography 10-16% Slope to Back

Depth to Water Table 25

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 6
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS Sandy Type Clay - Advise Builder to leave area for additional drainfield if needed.

CERTIFICATE OF COMPLETION BY Glenn Ford Jr DATE 2/23/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold