IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Brothers DATE 4/19/79 PERMIT NO.

PHONE: Business Home

LOCATION 70 E, T.R on 1st street past Shiloh Ch. Rd, house 200ft on left. S. R. No.


SUBDIVISION NAME Beaver Farms LOT NO. 73 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	120 gpd
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 1 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hope Bros.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 4/19/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold