IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hyatt Hill Methodist Church DATE 25 Oct 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 70 E. to Wagnile - across Hwy from Wagnile Grocery

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO _____

House ( ) Mobile Home ( ) Business ( ) Other Church Approx 200 Capacity

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Sand Clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	None
Auto. Wash. Machine	Yes ( )	No ( )	Topography	Slope to Hwy 70
Site Suitable	Yes ( )	No ( )	Depth to Water Table	Ent
			Rock or other impervious formations	L

Lot Area _____



Plot of System Hwy 70 E.

Existing Tank
Size of Tank (1000)' Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: New Tee in old Tank - good Slope.

CERTIFICATE OF COMPLETION BY Wm Howard DATE 25 Oct 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold